



# Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 557  
VERSION: 1

**SUBJECT: EC 7.30 HOT WATER TEMPERATURES – DOMESTIC**

---

**POLICY:** EC 7.30

The hot water temperatures will be checked daily.

**PURPOSE:**

To ensure the proper water temperatures are maintained throughout the facility.

**PROCEDURE:**

**MACC:**

The plumber will check the hot water temperatures daily, to make sure in all areas of the facility the hot water temperature shall be a minimum of 105 deg Fahrenheit, and a maximum of 120 deg Fahrenheit.

**KITCHEN:**

The hot water temperature within the kitchen shall be a minimum of 120 deg Fahrenheit, and a maximum of 125 deg Fahrenheit.

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/28/2014	Original Date: 01/04/1994
Reviewed: 03/29/2016	Next Review Date: 03/29/2017
Supersedes:	