# LAC+USC MEDICAL CENTER SAFETY POLICY

				Page 1	Of	2	
Subject:		Original		Policy #			
HOLIDAY DECORATIONS		Issue Date:	ue Date: 1993		SP 122		
HOLIDAT DECORATIONS		Supersedes:		Effective Date:			
		March	2019	March 20	)22		
Departments Consulted:	Reviewed & Approved	l by:	Approved by:				
	(Signature on File) Safety Officer		(Signature on Fil Director, Facilities Manager		•	t	

#### **PURPOSE**

To ensure fire safety during the holiday seasons.

#### **POLICY**

The LAC+USC Medical Center shall enforce and comply with local Fire Code and NFPA Life Safety Code for holiday decorations.

## **PROCEDURE**

The following requirements are applicable to all places of employment, assemblage and institutions, public lobbies, and other occupancies where the public is admitted or invited.

- All holiday decorations are non-combustible and have available proof of a current fire resistance certificate.
- Do not bring old decorations from home that are dry, brittle, or are deteriorated.
- It is strongly recommended not to use any decorations that are over three years old.
- Do not gift wrap doors.
- Candles in/on decorations are not permitted.
- Do not hang decorations from ceilings, doorways, or in front of elevators. If ignited, these could impede the safe and rapid evacuation from an area.
- The use of natural Christmas trees is **prohibited**. Artificial trees must be accompanied by valid proof of fire resistance issued for each tree.
- **Do not use electric lights**. In addition to posing a potential fire hazard, these lights tax an already overloaded electrical system.
- The use of battery-powered lights is permitted.
- Do not use extension cords to power holiday decorations.

**DISTRIBUTION: LAC+USC Medical Center Safety Policy Manual** 

		Page	2	Of	2
Subject: HOLIDAY DECORATIONS	Effective Date: March 2022	Policy # SP 122			
HOLIDAT DECORATIONS					

- Do not install holiday decorations that interfere with firefighting equipment or fire extinguishers. A minimum of 3 feet clearance must be maintained.
- Store holiday decorations safely. Store them 18 inches below sprinkler heads or 36 inches below unsprinklered ceiling.

### REFERENCE:

- Los Angeles City Fire Code 57.22.04
- NFPA 101 Life Safety Code 10.3.5 and A10.3.5

**REVIEW/REVISION DATE** - 02/99, 11/03, 07/04, 12/07, 12/10, 03/13, 03/16, 03/19, 03/22