



Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 542
VERSION: 1

SUBJECT: EC 5.40.18 TESTING OF THE AUTOMATIC FIRE EXTINGUISHING SYSTEM

POLICY: EC 5.40.18

It is the policy of the Facilities Division to ensure that the automatic fire extinguishing equipment is tested in accordance with Regulatory compliance and NFPA 25 standards on at least an annual basis.

PURPOSE:

The purpose of this policy is to require inspection and testing of the automatic fire extinguishing equipment accordance with all Regulatory compliance, NFPA 25 standards.

PROCEDURE:

The MACC’ s automatic fire extinguishing systems are inspected and tested (with or without discharge) on a regular basis.

Systems to be tested are as follows:

- Fire Sprinklers (MACC)
- Backflow devices (MACC)
- Dry Chemical (Kitchen)
- Water Flow Bell
- Data Center Clean Chemical system
- Risers and Standpipes

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/28/2014	Original Date: 01/04/1994
Reviewed: 03/29/2016	Next Review Date: 03/29/2017
Supersedes:	