



# Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 550  
VERSION: 1

## **SUBJECT: EC 7.10.12 CORRECTIVE PROCEDURE FOR WATER FAILURE/COMTAMINATION**

---

### **POLICY: EC 7.10.12**

Facilities will identify and implement emergency procedures in the event of a domestic water failure or contamination.

### **PURPOSE:**

Identify an alternative means of meeting the buildings essential utility needs during an emergency. This procedure is to be followed during regular working hours to maintain uninterrupted service at all times.

### **PROCEDURE:**

#### **FACILITIES OFFICE**

- A. Upon knowledge of water failure/contamination from a reliable source in the facility, issue instructions to the plumber to proceed as follows:
  1. Check the main valves.
  2. Determine if there is any malfunction.
- B. In case of any water interruption, immediately notify a plumber.

#### **PLUMBER**

- A. Proceed according to above instructions.
- B. If the trouble is not determined, report back to the Facilities office with progress updates and wait for further instructions, if necessary.

**NOTE: EMERGENCY WATER CAN BE OBTAINED FROM THE SAFETY OFFICE.**

<b>POLICY NO:</b> 550	<b>SUBJECT:</b> EC 7.10.12 CORRECTIVE PROCEDURE FOR WATER FAILURE/COMTAMINATION	<b>Page 2 of 2</b>
--------------------------	---	--------------------

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/28/2014	Original Date: 01/04/1994
Reviewed: 03/29/2016	Next Review Date: 03/29/2017
Supersedes:	