



Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 560
VERSION: 1

SUBJECT: EC 7.40.3 BATTERY POWERED EMERGENCY LIGHTS

POLICY: EC 7.40.3

Battery powered emergency lights, will be maintained and tested on a regular basis, as per Regulatory compliance, The Joint Commission compliance and NFPA requirements.

PURPOSE:

To ensure reliable and proper operation of all battery operated emergency lights.

PROCEDURE:

Battery powered emergency lights, will be maintained and tested on a regular basis, as per Regulatory compliance, The Joint Commission compliance and NFPA requirements.

These functional tests will consist of a 30 second test every 30 days, and a 90 minute test every 12 months.

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/28/2014	Original Date: 01/04/1994
Reviewed: 04/11/2016	Next Review Date: 04/11/2017
Supersedes:	