



Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 561
VERSION: 1

SUBJECT: EC 7.40.7 Failed Testing of Emergency Powered Equipment

POLICY: EC 7.40.7

If any emergency power equipment, required in EC 7.40 and maintained by the Facilities Department fails any test, the Facilities Department will perform a retest after making the necessary repairs.

PURPOSE:

To ensure all emergency power equipment is functioning properly after any repair.

PROCEDURE:

As per The Joint commission, after making any necessary repair, retest the equipment to ensure proper operation.

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/28/2014	Original Date: 01/04/1994
Reviewed: 03/29/2016	Next Review Date: 03/29/2017
Supersedes:	