



Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 492
VERSION: 1

SUBJECT: DOMESTIC HOT WATER AND TEMPERATURES

POLICY:

The hot water temperatures will be checked daily.

PURPOSE:

To ensure the proper water temperatures are maintained throughout the facility.

PROCEDURE:

The plumber will check the hot water temperatures daily, to make sure the hot water temperature shall be a minimum of 105 deg Fahrenheit and a maximum of 120 deg Fahrenheit, in all areas of the facility

KITCHEN:

The hot water temperature within the kitchen shall be a minimum of 120 deg Fahrenheit, and a maximum of 125 deg Fahrenheit.

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/25/2013	Original Date: 01/04/1994
Reviewed: 04/11/2016	Next Review Date: 04/11/2017
Supersedes:	