



Department of Facilities POLICY AND PROCEDURE

POLICY NUMBER: 541
VERSION: 1

SUBJECT: EC 5.40.17 TESTING OF THE AUTOMATIC FIRE DETECTION SYSTEM

POLICY: EC 5.40.17

It is the policy of the Facilities Division to ensure that fire safety equipment and all of its components are inspected at least annually and maintained in accordance with The Joint Commission and NFPA 25 standards.

PURPOSE:

The purpose of this policy is to require inspection and testing of the automatic fire detection equipment and all of its components in accordance with The Joint Commission and NFPA 25 standards.

PROCEDURE:

The MACC’ s automatic fire detection systems are inspected and tested at least annually.

Systems to be tested are as follows:

- Fire/Smoke Dampers
- Fire Doors
- All associated alarm systems.

Approved By: Anthony Corliss (MANAGER I, FACILITIES OPERATIONS AND CRAFTS)	
Date: 11/28/2014	Original Date: 01/04/1994
Reviewed: 04/11/2016	Next Review Date: 04/11/2017
Supersedes:	