

**VALLEYCARE**  
**OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS**  
**DEPARTMENT: FACILITIES**  
**POLICY & PROCEDURE**

**NUMBER: 515**  
**VERSION: 1**

**SUBJECT/TITLE: FAILURE OF CO-GENERATION PLANT**

**POLICY:**

**PURPOSE:** In the event of a failure of the high temperature hot water system, a vendor specializing in package units can supply units within a 24-hour period.

**PROCEDURE:** Air compressors, which are portable, can be obtained from a source vendor also. To obtain a portable air compressor for emergency use contact:

ISD – Facilities  
(213) 974-9555 (24 hours)  
(213) 974-1234 (operator-24 hours)

To obtain emergency high temperature hot water boilers contact:

Nation Wide Boiler Inc.  
Fremont, CA  
Gary Bliss  
(415) 490-7100

**INFORMATION** The Co-Generation Plant supplies the hospital with high temperature hot water for all heating and cooling of air spaces and hot water. Compressed air for pneumatic controls is also supplies for this area.

**DEPARTMENTS: FACILITIES**

**DEFINITIONS:**

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: <b>07/12/2015</b>	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	