

VALLEYCARE
OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS
DEPARTMENT: FACILITIES
POLICY & PROCEDURE

NUMBER: 528
VERSION: 1

SUBJECT/TITLE: CONDENSATE RETURN PUMPS

POLICY: Monthly check condensate pumps for proper operation.

PROCEDURE: Check condensate pumps for condensate leaks. Check pump motors for unusual noise.

EMERGENCY PROCEDURE: If condensate pump fails, replace with back-up unit. If electric motor fails replace with back-up unit.

PURPOSE:

DEPARTMENTS: FACILITIES

DEFINITIONS:

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: 07/12/2015	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	