

**VALLEYCARE**  
**OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS**  
**DEPARTMENT: FACILITIES**  
**POLICY & PROCEDURE**

**NUMBER: 541**  
**VERSION: 1**

**SUBJECT/TITLE:** STEAM TRAPS

**POLICY:** Check steam traps quarterly.

**PROCEDURE:** Check all steam traps for proper operation. Blow down inlet strainer.

**EMERGENCY PROCEDURE:** If steam traps fail, replace with spare back-up steam trap.

**PURPOSE:**

**DEPARTMENTS:** FACILITIES

**DEFINITIONS:**

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: <b>08/12/2012</b>	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	