

VALLEYCARE
OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS
DEPARTMENT: FACILITIES
POLICY & PROCEDURE

NUMBER: 587
VERSION: 1

SUBJECT/TITLE: CUSTODIAL EQUIPMENT

POLICY: All custodial equipment will have an electrical safety test annually.

PURPOSE:

PROCEDURE: The electrical safety will be conducted with a leakage current meter with a leakage not greater than 500 microamps. A visual test will be made of all cords and caps.

DEPARTMENTS: FACILITIES

DEFINITIONS:

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: 07/12/2015	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	