

VALLEYCARE
OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS
DEPARTMENT: FACILITIES
POLICY & PROCEDURE

NUMBER: 594
VERSION: 1

SUBJECT/TITLE: EMERGENCY SYNCHRONIZING SWITCHBOARD

POLICY: The emergency synchronizing switchboard is observed and maintained yearly.

PURPOSE:

PROCEDURE: The operator at the time of each test will observe and check for defective.

1. Indicating lamps and instrumentation and protective devices.
2. Devices and components.
3. Terminal connections.
4. Timing of power transferring.
5. Any accumulation of foreign objects.
6. Operational performance.
7. Exterior and interior cleanliness and condition of switchgear and switchgear housing.

DEPARTMENTS: FACILITIES

DEFINITIONS:

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: 07/12/2015	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	