

VALLEYCARE
OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS
DEPARTMENT: FACILITIES
POLICY & PROCEDURE

NUMBER: 650
VERSION: 1

SUBJECT/TITLE: FIRE HOSE CABINETS

POLICY: The contents of the fire hose cabinets are checked quarterly. Fire hose valves are flow-tested annually.

PURPOSE:

DEPARTMENTS: FACILITIES

DEFINITIONS:

PROCEDURE:

QUARERLY PROCEDURE: Open the hose cabinet. Check for damage, theft, loose fittings, leaks and torn or mildewed hoses.

ANNUAL PROCEDURE: The fire hose is disconnected from the valve. The valve is opened and water is run into a container.

FIVE (5) YEAR PROCEDURE: Fire hoses are to be replaced every five (5) years.

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: 07/12/2015	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	