

VALLEYCARE
OLIVE VIEW-UCLA MEDICAL CENTER/HEALTH CENTERS
DEPARTMENT: FACILITIES
POLICY & PROCEDURE

NUMBER: 653
VERSION: 1

SUBJECT/TITLE: HOT WATER CIRCULATING PUMPS

POLICY: Check operation monthly.

PURPOSE:

DEPARTMENTS: FACILITIES

DEFINITIONS:

PROCEDURE: Check to see that the valves are in the open position and the pump is running.
There should be little audible noise.

Turn off motor and inspect coupling for wear. Motor bearing are to be oiled with 3-5 drops of oil. Pumps bearings with 10-15 drops.

QUALITY ASSURANCE: Place a hang on a water line coming from the pump to make sure that hot water is circulating.

References:	
Approved by: Robert Ross (Director, Facilities)	Date: 08/12/2009
Review Date: 07/12/2015	Revision Date:
Distribution: Facilities	
Original Date: 08/12/2009	